

# Evaluation of Sorbent Injection for Mercury Control



Public Service  
of New Hampshire  
The Northeast Utilities System

**EUEC 2007**

January 21 - 24, 2007



DOE Cooperative Agreement DE-FC26-06NT42780  
DOE/NETL Project Manager: Andrew O'Palko



# Test Team

---

- DOE/NETL
- PSNH
- ADA-ES
- Reaction Engineering International
- Other Support
  - Breen Technology – Dew point monitors
  - E.ON Engineering – SO<sub>3</sub> Measurements
  - Air Sampling Associates – Manual Measurements
  - Lab analysis, etc.

# DOE Project Focus Areas

---

- Evaluate effectiveness of sorbent injection for mercury control in unproven environments
  - Cyclone Boiler
  - SCR on a medium sulfur flue gas – 1.2% coal blend
  - Mid-sized ESPs, Injection between ESPs
  - High SCR generated SO<sub>3</sub> flue gas
  - Co-control for SO<sub>3</sub> and Hg
  - Temperature effects on ACI in the 300 – 350°F range

# Project Goals

---

*Reduce the uncontrolled mercury emissions by 50 to 70% at a cost 25 to 50% lower than DOE basis (\$60,000/lb Hg removed)*

- Determine process/equipment costs for various levels of mercury removal
- Quantify balance-of-plant impacts
- Evaluate the capability of SO<sub>3</sub> tolerant sorbents to achieve 70 to 90% mercury removal
- Evaluate the effect of co-benefits from SO<sub>3</sub> mitigation on mercury control, and the balance of plant benefits from lowered flue gas temperatures including increased plant efficiency and overall reduced emissions
- Evaluate the impact of sorbent injection on ash disposal
- Support the education and transfer of information and results to local and state interests groups

# PSNH Merrimack Station

Unit Capacity

335 MW

Test Portion

335 MW

Coal

Bituminous/Venezuelan 1/1  
Blend for 1.2% S

Hg Content:

0.04 – 0.1 ppm-dry

Cl Content:

~750 ppm-dry

SO<sub>2</sub> Control – Low sulfur coal  
blends


APH – Tubular Design

Particulate Control – 2 ESPs in  
series (120, 230 SCA)




**Testing Began September 2006**

# Merrimack Unit 2 Overall Layout



# ***Co-Benefit Testing***

# Effect of SO<sub>3</sub> on Sorbent Capacity: Fixed-bed Results




*REI Model suggests capacity > 1500 to 2000 µg/g is needed for good Hg capture in an ESP*

\*Not Tested at Merrimack

***Equilibrium Adsorption Capacities Upstream and Downstream of SO<sub>3</sub> Injection for FGC***

# Effect of SO<sub>3</sub> – Plant Daniel

*Mississippi Power Plant Daniel  
Low sulfur Bituminous Coal with  
PRB, SO<sub>3</sub> Injection for ESP  
Performance Improvement*



# SO<sub>3</sub> Measurements

---

- **Manual Measurements**
  - **Baseline Test Period**
    - **Downstream of the APH: 10 – 16ppm**
  - **Trona Injection (Measured Inter-ESP)**
    - **Pre-Injection (Inter-ESP): 13 – 17ppm**
    - **Trona at 500lb/hr: 5 - 10ppm**
    - **Post-Injection (Inter-ESP): 20ppm**
- **Breen Energy Solutions In-Situ Monitor**
  - **Trona Injection**
    - **Indicate <10ppm SO<sub>3</sub> Levels**

# Comparison of SO<sub>3</sub> Sorbents

---

- **Cost comparison of MgO vs Trona**
  - **Trona –**
    - \$85/ton – Wyoming
    - Injection rate of 500 – 625lb/hr
  - **MgO –**
    - \$780/ton
    - Injection rate of 180lb/hr
- **Comparison of effects on ESP performance**
  - **MgO –**
    - Power levels in Original ESP drop from average of 12 to 5kW
    - Opacity at 180lb/hr increased to above 15% from 10%
  - **Trona –**
    - Power levels unaffected
    - Opacity increase of 2%

# ***Baseline Results***


# Baseline Results

---

- Hg varies (range was 5 to 10  $\mu\text{g}/\text{m}^3$  from Aug 06 through Jan 07)
- No removal across the ESP
  - Based on CEM, STM
  - Low Hg levels in ash analysis (10 ppb)
- OH within 20% of Baseline CEM and STM results
- On and off site analysis of STM traps correlate well with inlet CEM
- Outlet CEM reads 0.5 – 2  $\mu\text{g}/\text{m}^3$  higher than inlet, when manually corrected – trend together
- >80% Oxidation of Mercury

# Baseline Mercury Trends

Pre-Baseline and Baseline



# ***Parametric Sorbent Injection***


# Finding the Right Sorbent

---


- Evaluate various sorbents
  - Fixed-bed screening
  - Full-scale injection tests
- Assure good sorbent distribution
  - CFD Modeling
  - Stratification measurements
    - Outlet mercury grid
    - Variations in hopper LOI and Hg
- Assure good mercury measurements
  - QA checks and RA measurements
  - Mass balance checks with coal and ash

# December 2006 Parametric Testing

PAC Injection between ESPs, No SO<sub>3</sub> Mitigation, Normal APH Outlet Temp – 330-350°F



# Parametric Test Results



# Future Testing at Merrimack Unit 2

---

- Dual Injection of MgO with PAC
  - Low level injection of MgO
    - Start at 30lb/hr, increase to 60 and 90lb/hr
    - Above 90lb/hr, significant immediate impact on ESP performance
  - Without full SO<sub>3</sub> absorption, restricted ability to lower APH outlet temperatures
    - Impact on PAC Hg removal
    - Three potential sorbents
      - DARCO Hg
      - DARCO Hg-LH
      - DARCO E-26



# ***Issues***

# CCB and Other General Issues

---

- The mercury captured by activated carbon, LOI carbon, and ash appears to be very stable and unlikely to leach into the environment.
- The presence of activated carbon in ash will most likely prevent sale for use in concrete.
  - Several developing technologies to address the problem
- Low level bromine leaching from ash mixed with treated carbon
  - *How significant is this?*
- Secondary stack emissions measured due to treated sorbent injection

# Questions/Discussion

---

Tom Campbell  
ADA-ES  
(303) 339-8864  
[tomc@adaes.com](mailto:tomc@adaes.com)

Paul Raichle  
PSNH Merrimack Station  
(603) 224-4081 x182  
[raichpr@NU.com](mailto:raichpr@NU.com)

Andrew O'Palko  
DOE NETL  
(304) 285-4715  
[andrew.opalko@netl.doe.gov](mailto:andrew.opalko@netl.doe.gov)