

Mercer Commercial Mercury Control Project: Results

Edward Augustyn, PSEG



Electric Utilities Environmental Conference
January 30, 2008



Overview

- Regulatory Drivers
- Unit Description
- Review of Performance Testing Results
- Operating Experience

Current Timing & Technology

	Emission Limits
SCR (NO _x) Baseline 1.4 lb/mmBtu	0.100 lb/mmBtu (90 day) 0.130 lb/mmBtu (30 day) 0.150 lb/mmBtu (24 hour)
Dry Scrubber (SO ₂) Baseline – 2.5-3.0 lb/mmBtu	0.150 lb/mmBtu (30 day) 0.250 lb/mmBtu (24 hour)
Baghouse (PM) Baseline – 0.3 lb/mmBtu	0.0150 lb/mmBtu
Carbon Injection (Mercury) Baseline – 38 mg/MWhr-net or 9 ug.Nm ³	90% Reduction or 3 mg/MWhr-net Whichever is less stringent

SCR – Complete – Summer 2004

Carbon Injection – Complete – January 2007

Baghouse and Carbon Relocation – December 31, 2008

Scrubber – December 31, 2010


Mercer Unit 2

- PSEG Mercer Unit 2
 - 315 MW net (333 MW gross)
 - Bituminous Blend
 - Venezuelan (50%)
 - Hg: 0.021 to 0.088 ppm*
 - Cl: 190 to 433 ppm*
 - Virginia Pocahontas (50%)
 - Hg: 0.039 to 0.074 ppm*
 - Cl: ~ 970 ppm*
- Cold Side ESP
- PAC Injection system installed in 2006




** Results from 11/06 through 2/07 analyses*


Variability of Mercury in Coal





Overall Plant – Gas Path



Units 1 and 2 General Arrangement



-  SCEM Measurement (Parametric)
-  Modified Appendix K Measurement (Parametric, Long-Term)

Carbon Injection Silo




System provided by ADA-ES


Designed for up to 18 lb/MMacf
(xx lb/hr)

Storage capacity xxx days

PAC Injection Feeders and Grid




Results from Performance Testing



Performance testing conducted by URS

Results from Performance Testing



Performance testing conducted by URS

Results Comparison

COMPARISON OF OLD TEST VS CURRENT TEST, DARCO Hg

Coal	System	Baseline Hg (mg/MWh net)	Percent Reduction	Hg Emissions (mg/Mwhnet)
Domestic	Demo	18-27	84%	3.1
50/50	Demo	11-12	67%	4.2 – 4.3
50/50	Commercial	11-20	78% - 87%	1.4-2.5

Data for injection rates > 10 lb/MMacf

Balance of Plant

- No increase in opacity
- No change in precipitator performance
- Some handling issues with RWE HOK



Plastic in Delivered Carbon



Erosion

Summary

Baseline Mercury Content

- Domestic baseline is high (>20 mg/MW hr)
- 50/50 baseline is lower (10 – 20 mg/MW hr)

Sorbent Requirements

- Good results when > 10 lb/MMacf
- Marginal Benefits over 12lb/MMacf

NJDEP Requirements Achieved

Percent Reduction

(90% Limit)

78 – 87%

- or -

Emission Limit

(3 mg/MW hr net)

1.4 to 2.5



Balance of Plant

- No change in ESP performance or opacity
- Materials handling issues with some sorbents